

# Formaldehyde Emission Test Certificate

Monday February 7<sup>th</sup>, 2022

Supplier: Australian Select Timber (61-63 Discovery Road, Dandenong, VIC, 3175, Australia)

Sample Description: Artistry Collection - Couture Oak

Date Tested: December 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

**Emission Data (7 days exposure):**

<p><b>Green Building Council of Australia</b> Green Star Design &amp; As Built v1.3 13.1.2B &amp; 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p><b>Artistry Collection - Couture Oak</b></p>
<p>Formaldehyde Emission Rate limit: <math>\leq 0.1 \text{ mg/m}^2/\text{hr}</math></p>	<p>Formaldehyde Emission Rate: <math>0.060 \text{ mg/m}^2/\text{hr}</math></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Luke Morley  
BSc (Technology)  
Consultant



Dr. Tuan Duong  
PhD, B Eng. (Chem.)  
Senior Consultant

V2112024Ver1