

# TVOC Emission Test Certificate

Monday February 7<sup>th</sup>, 2022

Supplier: Australian Select Timber (61-63 Discovery Road, Dandenong, VIC, 3175, Australia)

Sample Description: Artistry Collection - Couture Oak

Date Tested: December 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

**Emission Data (24 hrs exposure):**

<p align="center"><b>Green Building Council of Australia</b> Green Star Design &amp; As Built v1.3 13.1.2B &amp; 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center"><b>Artistry Collection - Couture Oak</b></p>
<p align="center">Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m<sup>2</sup>/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.009 mg/m<sup>2</sup>/hr</p>
<p align="center">4-phenylcyclohexene Emission Rate limit: &lt;0.05mg/m<sup>2</sup>/hr</p>	<p align="center">4-phenylcyclohexene Emission Rate: &lt;0.002 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Luke Morley  
BSc (Technology)  
Consultant



Dr. Tuan Duong  
PhD, B Eng. (Chem.)  
Senior Consultant

V2112024 Ver1