

Emission Test Certificate

Wednesday November 25th, 2020

Supplier: Australian Select Timbers Pty Ltd (136 Atlas Boulevard, Dandenong South VIC, 3175, Australia)

Sample Description: Aurora European Oak

Date Tested: March 2014 (Tested through FORAY Laboratories - NATA Accreditation 1231)


Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (24 hrs exposure):

| | |
|--|---|
| <p>Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p> | <p>Aurora European Oak</p> |
| <p>Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m²/hr</p> | <p>Total Volatile Organic Compound Emission Rate: 0.008 mg/m²/hr</p> |
| <p>4-phenylcyclohexene Emission Rate limit: <0.05mg/m²/hr</p> | <p>4-phenylcyclohexene Emission Rate: <0.005 mg/m²/hr</p> |
| <p>Formaldehyde Emission Rate limit: ≤ 0.1 mg/m²/hr</p> | <p>Formaldehyde Emission: <0.007 ppm</p> |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Srikanth C. Srivatsa
PhD (Chemistry)
Consultant



Tuan Duong
PhD (Chemical Eng.)
Senior Consultant

V2011075