

Fire & Smoke Test Certificate

Thursday November 12th, 2020

Supplier: Australian Select Timbers Pty Ltd (61-63 Discovery Road, Dandenong, VIC 3175)

Sample Description: T-series Flooring board

Date Tested: March 2015 (Tested by Laboratories – NATA Accreditation N^o: 1356)

Test Method: AS/ISO 9239-1:2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.


Test Result:

AS/ISO 9239-1:2003	T-series Flooring board
Critical Heat Flux/Critical Radiant Flux*	5.0 kW/m ²
Smoke Development Rate (SDR Value) *	11 %.min
Penetration of flame through to substrate	Yes
Glowing	Yes
Smoldering	Yes

*Three test average value



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Srikanth C. Srivatsa
PhD (Chemistry)
Consultant



Dr. Tuan Duong
PhD (Chemical Engineer)
Senior Consultant

CV150326 R01