

# Emission Test Certificate

Friday, April 17<sup>th</sup>, 2015

Supplier: Australian Select Timbers Pty Ltd (61-63 Discovery Road, Dandenong, VIC 3175)

Sample Description: T-series

Date Tested: March 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p align="center"><b>Green Building Council of Australia Green Star Office Design v3 IEQ-13</b></p>	<p align="center"><b>T-series</b></p>
<p>Total Volatile Organic Compound Emission Rate limit &lt;0.5mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.008mg/m<sup>2</sup>/hr</p>
<p>4-phenylcyclohexene Emission Rate limit &lt;0.05mg/m<sup>2</sup>/hr</p>	<p>4-phenylcyclohexene Emission Rate: &lt;0.005mg/m<sup>2</sup>/hr</p>
<p>Formaldehyde Emission Rate limit &lt;0.1mg/m<sup>2</sup>/hr</p>	<p>Formaldehyde Emission Rate: &lt;0.007mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV150326**