

VOC Emission Test Certificate

Monday August 16th, 2021

Supplier: Australian Select Timbers (136 Atlas Boulevard, Dandenong South, VIC, 3175, Australia)

Sample Description: KODIAK K186 Scenic Flooring Board

Date Tested: 08 August 2021 (Tested by Foray Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs exposure):

<p>Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p>KODIAK K186 Scenic Flooring Board</p>
<p>Total volatile organic compound Emission rate limit: ≤ 0.500 mg/m²/hr</p>	<p>Total volatile organic compound Emission rate: 0.011 mg/m²/hr</p>
<p>Formaldehyde Emission rate limit: ≤0.100 mg/m²/hr</p>	<p>Formaldehyde Emission rate: 0.013 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr Tuan Duong
PhD, B Eng. (Chem.)
Senior Consultant

V2108016