

Emission Test Certificate

Thursday 13th April 2023

Supplier Australian Select Timbers Pty Ltd (136 Atlas Boulevard, Dandenong South, VIC, 3175, Australia).

Product Name Kodiak Lite Collection Vinyl Plank

Date Tested March 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours)

<p align="center">Green Building Council of Australia</p> <p align="center">Green Star Design & As Built V1.3 13.1.2B & 13.2</p> <p align="center">Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">Kodiak Lite Collection Vinyl Plank</p>
<p>Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.118 mg/m²/hr</p>
<p>Formaldehyde Emission Rate Limit: ≤0.100 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.011 mg/m²/hr</p>



Dr. Vyt Garnys
Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr Tuan Duong
Ph.D., B.Eng. (Chemical)
Senior Consultant

Issued Date: 13/04/2023

Expired Date: 13/04/2028

P23020012