

# VOC Emission Test Certificate

Friday 22<sup>nd</sup> August 2025

Supplier: Australia Select Timbers Pty Ltd (136 Atlas Boulevard, DANDENONG SOUTH, VIC, 3176, AUSTRALIA).

Product Name: American Oak 14mm

Date Tested: 26<sup>th</sup> July 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2025 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

## Test Data (24 hrs):

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	American Oak 14mm
Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate Limit: ≤0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate: 0.009 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: 0.040 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant