

Emission Test Certificate

Friday March 01st, 2019

Supplier: Australian Select Timber (61-63 Discovery Road, Dandenong, VIC, 3175, Australia)

Sample Description: Nouvelle Hybrid Rigid Flooring Board

Date Tested: February 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-17 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products”.

Emission Data (24 hrs exposure):

| | |
|--|---|
| <p>Green Building Council of Australia Green Star Design & As Built v1.1 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p> | <p>Nouvelle Hybrid Rigid Flooring Board</p> |
| <p>Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m²/hr</p> | <p>Total Volatile Organic Compound Emission Rate: 0.020 mg/m²/hr</p> |
| <p>Formaldehyde Emission Rate limit: ≤0.1 mg/m²/hr</p> | <p>Formaldehyde Emission Rate: <0.008 mg/m²/hr</p> |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV190201