

Formaldehyde Emission Test Certificate

Monday February 7th, 2022

Supplier: Australian Select Timber (61-63 Discovery Road, Dandenong, VIC, 3175, Australia)

Sample Description: Opulence Native Collection

Date Tested: December 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (7 days exposure):

<p>Green Building Council of Australia Green Star Design & As Built v1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p>Opulence Native Collection</p>
<p>Formaldehyde Emission Rate limit: $\leq 0.1 \text{ mg/m}^2/\text{hr}$</p>	<p>Formaldehyde Emission Rate: $0.063 \text{ mg/m}^2/\text{hr}$</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Luke Morley
BSc (Technology)
Consultant



Dr. Tuan Duong
PhD, B Eng. (Chem.)
Senior Consultant

V2112024 Ver1