

TVOC Emission Test Certificate

Friday January 7th, 2022

Supplier: Australian Select Timber (61-63 Discovery Road, Dandenong, VIC, 3175, Australia)

Sample Description: Opulence Native Collection

Date Tested: December 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (24 hrs exposure):

<p align="center">Green Building Council of Australia Green Star Design & As Built v1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">Opulence Native Collection</p>
<p align="center">Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.016 mg/m²/hr</p>
<p align="center">4-phenylcyclohexene Emission Rate limit: <0.05mg/m²/hr</p>	<p align="center">4-phenylcyclohexene Emission Rate: <0.003 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Luke Morley
BSc (Technology)
Consultant



Dr Tuan Duong
PhD, B Eng. (Chem.)
Senior Consultant

V2112024Ver1