

Emission Test Certificate

Thursday February 15th, 2018

Supplier: Australian Select Timbers (PO Box 4320, Dandenong South VIC 3164)

Sample Description: Australian Select Timbers Reflections Laminate Flooring

Date Tested: February 2018 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:


<p>Green Building Council of Australia</p> <p>Green Star Interiors v1.1 – 12.1.2B</p> <p>Green Star Office Design v1.1 – 13.1.2B</p>	<p>Australian Select Timbers Reflections Laminate Flooring</p>
<p>Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.024 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit: <0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.054 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV180135