

# Emission Test Certificate

Monday 24<sup>th</sup> November 2025

**Manufacturer** Australian Select Timbers Pty Ltd (136 Atlas Boulevard, Dandenong South, VIC, 3175, Australia).

**Product Name** Australian Select Timber Select Underlay \_ Acoustic Undelay 3mm.

**Date Tested** 18 November 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

**Test Method** ASTM D5116:2025 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

**Emission Data (24 hrs):**

<b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.2</b>	<b>Select Underlay</b> <b>Acoustic Undelay 3mm</b>
Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate Limit: ≤0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate: 0.235 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: ≤0.100 mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: <0.004 mg/m <sup>2</sup> /hr

Dr. Vyt Garnys  
PhD, BSc (Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Travis Hale  
BSc (Biotechnology)  
Senior Consultant

Dr. Tuan Duong  
PhD, B.Eng. (Chemical)  
Senior Consultant