

VOC Emission Test Certificate

Tuesday 7th July 2026

Supplier: Australian Select Timbers Pty Ltd (136 Atlas Boulevard, Dandenong South, VIC 3175, Australia).

Product Name: 12mm Laminate Flooring – Genco.

Date Tested: 18th June 2026 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116:2025 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Test Data (24 Hrs):

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	12mm Laminate Flooring – Genco
Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate: 0.006 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m ² /hr	Formaldehyde Emission Rate: 0.021 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant