CETEC Pty Ltd ABN 44 006 873 687
Melbourne | Sydney | Brisbane | Perth | London | San Francisco

VOC Emission Test Certificate

Tuesday 7th July 2026

Supplier: Australian Select Timbers Pty Ltd (136 Atlas Boulevard, Dandenong South, VIC 3175, Australia).

Product Name: 8mm Laminate Flooring – Lifestyle.

Date Tested: 18th June 2026 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116:2025 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Test Data (24 Hrs):

Specification **Green Building Council of Australia** **Green Star Design & As Built V1.3-13.1.1B** **Green Star Interiors V1.3-12.1.1B**	**8mm Laminate Flooring – Lifestyle**
Total Volatile Organic Compound (C_6-C_{16}) Emission Rate Limit: ≤0.500 mg/m^2/hr	Total Volatile Organic Compound (C_6-C_{16}) Emission Rate: 0.016 mg/m^2/hr
Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m^2/hr	Formaldehyde Emission Rate: 0.056 mg/m^2/hr

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 7/07/2026 **Expiry date: 7/07/2031** **P26060004**