

# Emission Test Certificate

Thursday, May 1<sup>st</sup>, 2014

Supplier: Australian Select Timbers (35 Downard Street, Braeside, VIC 3195)

Sample Description: Grand Oak

Date Tested: April 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p><b>Green Building Council of Australia</b> <b>Green Star Office Design v3 IEQ-13</b></p>	<p><b>Grand Oak</b></p>
<p>Total Volatile Organic Compound emission rate: &lt;0.5 mg/m<sup>2</sup>/hr</p>	<p>0.046 mg/m<sup>2</sup>/hr</p>
<p>4-phenylcyclohexene emission rate: &lt;0.05 mg/m<sup>2</sup>/hr</p>	<p>&lt;0.003 mg/m<sup>2</sup>/hr</p>
<p>Formaldehyde emission rate: &lt;0.1 mg/m<sup>2</sup>/hr</p>	<p>0.011 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

CV140425