

Acoustic Test Certificate

Wednesday, August 31st, 2016

Supplier: Australian Select Timbers Pty Ltd (61-63 Discovery Road, Dandenong South, VIC 3175)

Product Description: 2mm Foam Underlay

Test Method: AS/ISO 140:7-2006

Acoustic Test Data:

1/3 Octave Band Centre Frequency (Hz)	Impact Sound Pressure Level L'_{nT} (dB)	
	Base Floor	Engineered Timber with 2mm Foam on Base Floor
100	56.9	55.7
125	56.3	55.9
160	62.4	61.1
200	62.9	61.6
250	58.9	57.5
315	59.2	57.5
400	57.6	55.5
500	60.3	56.6
630	61.7	55.0
800	61.1	49.9
1000	62.2	45.8
1250	62.7	41.6
1600	62.6	37.3
2000	62.4	34.2
2500	63.0	36.7
3150	68.5	34.2
4000	70.4	32.5
5000	66.5	33.1
$L'_{nT,w}$ (C_I)	70 (-12)	53 (0)

The impact sound insulation performance of a system is denoted by a single value descriptor, the weighted impact sound insulation $L_{n,w}$ (for laboratory tested rating) or $L'_{nT,w}$ (for field tested rating). The single value descriptor allows for easy comparisons between different systems. The lower the number, the better the impact sound insulation performance.

The rating of the system is determined by comparing the measured noise levels in the receiving room against a set of reference values between one-third-octave band centre frequency ranges of 100Hz to 3150Hz, as specified in AS/NZS ISO 717.2-2004.

The base floor construction of 200mm concrete slab with 35mm furring channels and a single layer of 10mm standard plasterboard ceiling, achieved a weighted impact sound insulation rating of $L'_{nT,w}$ of 70.

The floor/ceiling system consisting the 2mm foam underlay and the 15mm engineered timber floor covering on top of the base floor achieved a weighted impact sound insulation rating of $L'_{nT,w}$ of 53, improving the base floor performance of $L'_{nT,w}$ by 17dB.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV160737